



ACM PANEL - GENERAL NOTES

- ALL ACM PANELS MUST BE ANCHORED TO MINIMUM 16 GA. STEEL TRUSS FRAMING. REFER TO STRUCTURAL DETAILS. STEEL FRAMING MUST BE BY CS SYSTEMS.
- BETWEEN STUDS MUST BE ALUMINUM ANGLE OR ALUMINUM CHANNEL REQUIRED FOR METAL PANEL ATTACHMENT.
- OVERLAP JOINTS MUST BE USED TO SUPPORT METAL COMPOSITE PANELS (S.C. TO COORDINATE).
- 5/8" x 3" x 16" SHEATHING AND/OR GLASS MAT SHEATHING WILL NOT SUPPORT METAL PANEL ATTACHMENT (SHEATHING NOT BY CS SYSTEMS).
- ALL METAL PANELS FABRICATED IN ACCORDANCE WITH THE FOLLOWING ASSOCIATED PANEL DETAILS TO BE PREPARED AS USUAL. COLOR TO MATCH NO. 1.
- ALL METAL COMPOSITE PANELS JOINTS ARE TO BE FIELD VERIFIED PRIOR TO THE FABRICATION AND SHIP OUT. ALL ALL METAL COMPOSITE PANELS JOINTS TO BE ASSOCIATED FLANGES.
- ALL SKYWARD ACH PANELS QUANTITY ARE TO HAVE BACKER ROD AND CALD. APPLY DOWN PAST WOOD BLOOMING. TYPE: BACKER ROD AND CALK AT ALL VERTICAL PANEL END (JAMB) JOINT
- USE BACKER ROD AND CALK AT ALL VERTICAL PANEL END (JAMB) CONNECTIONS AT DISMISSAL MATERIALS (E. JUTCO, DISMISSAL PANELS).
- ALL SKYWARD ACH PANEL, JOINTS ARE TO HAVE BACKER ROD AND CALD. APPLY DOWN PAST WOOD BLOOMING. TYPE: BACKER ROD AND CALK AT ALL VERTICAL PANEL END (JAMB) JOINT CONNECTIONS AT DISMISSAL MATERIALS (E. JUTCO, DISMISSAL PANELS).



WEST JENSEN PUD, PHASE 1B PARCEL 12
FIFTH THIRD BANK
4110 NW FEDERAL HWY
JENSEN BEACH, FL 34957

[illegible]

SEAL

3

ISSUE	BY	DATE	DESCRIPTION
1	EI	08/07/23	ISSUE FOR PERMIT
3	CR	02/06/24	SITE CRL
4	CR	04/29/24	SITE CRL ROUND 2

PROJECT INFORMATION BLOCK	
JOB #	220666
DATE:	08/07/23
DRAWN BY:	EL
CHECKED BY:	CR
SHEET TITLE	

EXTERIOR ELEVATIONS

SHEET NUMBER

A-200



A-200

ITEM	EXTERIOR FINISH	MANUFACTURER	COLOR	COMMENTS
ACM3	ALUMINUM COMPOSITE METAL PANEL	ALCOA ARCHITECTURAL REYNOLDS	CLEAR ANODIZED METAL	
AL-1	ALUMINUM CURTAINWALL SYSTEM	YKK AP AMERICA	CLEAR ANODIZED	
AL-2	ALUMINUM CURTAINWALL SYSTEM	YKK AP AMERICA	CLEAR ANODIZED	
EF32	GFS	ALUVIEW (FINE FINISH)	COVER SLAT	
EF33	MODULAR STANDARD BRICK VENEER	ACME BRICK	SLATE GRAY	MORTAR MANUFACTURER: COOSA. MORTAR COLOR: OLD LINE PUTTY
EF34	GRICK BRILL	ACME BRICK	SLATE GRAY	MORTAR MANUFACTURER: COOSA. MORTAR COLOR: OLD LINE PUTTY
EF35	GRICK BRILL	ACME BRICK	SLATE GRAY	MORTAR MANUFACTURER: COOSA. MORTAR COLOR: OLD LINE PUTTY
EXT-1	SHOULDERL Siding	JAMES HARDI	BALDIA SMIT	PAINT MANUFACTURER: BENJAMIN MOORE. COLOR: CC-27. SMOOTH FINISH
EXT-3	5.5" HARDI TRIM	JAMES HARDI	METROPOLIS	PAINT MANUFACTURER: BENJAMIN MOORE. COLOR: CC-54H. HARVEST TRIM 54 SMOOTH FINISH
EXT-4	12" CORNICE	CUSTOM	METROPOLIS	PAINT MANUFACTURER: BENJAMIN MOORE. COLOR: CC-54H
EXT-5	STANDING SEAM METAL ROOF SYSTEM	BERRIDGE	LEAD - COLE	
EXT-6	RAFTER TAILS	JAMES HARDI	METROPOLIS	PAINT MANUFACTURER: BENJAMIN MOORE. COLOR: CC-54H
EXT-7	11.25" HARDI TRIM	JAMES HARDI	METROPOLIS	PAINT MANUFACTURER: BENJAMIN MOORE. COLOR: CC-54H. HARVEST TRIM 54 SMOOTH FINISH
M-1	PREFINISHED METAL CORING	PAC-CLAD	ANODIC CLEAR	

257	A	ALL CPM PANELS MUST BE ATTACHED TO MINIMUM 6 IN. C/P METAL STUD FRAMING. REFER TO STRUCTURAL, METAL STUD FRAMING NOTED BY C/S SYSTEMS.
	B	METAL STUDS MUST ALSO JOIN WITH PANEL JOINTS AS REQUIRED FOR METAL COMPPOSITE PANEL ATTACHMENT.
	C	FIXED STUDS MUST BE USED TO SUPPORT METAL COMPPOSITE PANELS (C/S TO COORDINATE).
	D	SUPPLY AND INSTALL ALUMINUM STUDS WHERE NECESSARY. STUDS WILL NOT SUPPORT METAL COMPPOSITE PANEL ATTACHMENT (SHEATHING NOT BY C/S SYSTEMS).
	E	ALL PLATFOOR BACKSTAYING PLACING REQUIRED FOR METAL COMPPOSITE PANEL DETAILS TO BE SHOWN ON ALL PLATFOOR ALUMINUM.
258	A	ALL DIMENSIONS AND QUANTITIES ARE TO BE FIELD VERIFIED PRIOR TO THE FABRICATION AND INSTALLATION OF ALL METAL COMPONENTS.
	B	ALL SKIDWAY ANCHOR JOINTS TO HAVE BACKER ROD AND GASKET. APPLY DOWN PAINT WOOD BLOCKING.
	C	ALL SKIDWAY ANCHOR JOINTS TO HAVE BACKER ROD AND GASKET. APPLY DOWN PAINT WOOD BLOCKING.
	D	ALL SKIDWAY ANCHOR JOINTS TO HAVE BACKER ROD AND GASKET. APPLY DOWN PAINT WOOD BLOCKING.
	E	ALL SKIDWAY ANCHOR JOINTS TO HAVE BACKER ROD AND GASKET. APPLY DOWN PAINT WOOD BLOCKING.

[illegible]

ISSUE	BY	DATE	DESCRIPTION
1	EI	08/07/23	ISSUE FOR PERMIT
3	CR	02/06/24	SITE CRL
4	CR	04/29/24	SITE CRL ROUND 2

EXTERIOR ELEVATION

A-201



A-201